



136 Cannon Street West
 Hamilton, ON L8R 2B9
 Tel: (905) 528-0241
 Fax: (905) 667-0210

FUEL OIL DISTRIBUTOR INSPECTIONS

Aboveground Tanks - Inside

Owner/Operator	
Location	Tel:
Owner's Address (if different from above)	

Note: Inspection is limited to external observation of tanks and components in their operating position.

	1st TANK	2nd TANK
Type of Tank i.e. (ULC-S602)		
Manufacturer		
Date of Manufacturer or Age in Years		
Serial No.		
1. Is the tank approved for its present use?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Does the tank appear to have been installed in accordance with the fuel oil code, the certification document and the manufacturer's instructions?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Are the tank vent and fill pipes properly installed and terminated?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Is the tank equipped with a proper fill cap?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. Is the tank equipped with a proper gauge and overfill protection device (whistle)?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
6. Is the tank properly supported on a firm base?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
7. Is the tank support system in good condition, non-combustible and stable?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
8. If two tanks are joined, are they installed on a common slab?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
9. If two tanks are bottom connected, are they connected with 2 in. pipe?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
10. Is the system free of leaks or any signs of weepage?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
11. Is the tank and piping painted or coated to prevent external corrosion?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
12. Are burner supply/return lines free of compression fittings?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
13. Are burner supply/return lines installed above grade and protected or underground and chased?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
14. Are burner supply/return lines installed to code?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
15. Is an approved shut-off valve installed?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
16. Is an approved filter installed with a temperature rating above 538°C (1000°F)?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
17. Is the fill/vent pipe steel or galvanized construction?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
18. Is the tank located at least 5 feet from the appliance or is the tank protected from the appliance by a fire rated wall?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTES: (any "NO" answers must be explained in this section and the affected equipment repaired, replaced or tagged)

Comments 	Technician's Signature _____ Certificate No. Date
----------------------	--



136 Cannon Street West
 Hamilton, ON L8R 2B9
 Tel: (905) 528-0241
 Fax: (905) 667-0210

FUEL OIL DISTRIBUTOR INSPECTIONS

Aboveground Tanks - Outside

Owner/Operator	
Location	Tel:
Owner's Address (if different from above)	

Note: Inspection is limited to external observation of tanks and components in their operating position.

	1st TANK	2nd TANK
Type of Tank i.e. (ULC-S602)		
Manufacturer		
Date of Manufacturer or Age in Years		
Serial No.		
1. Is the tank approved for it's present use?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Does the tank appear to have been installed in accordance with the fuel oil code, the certification document and the manufacturer's instructions?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Are the tank vent and fill pipes properly installed and terminated?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Is the tank equipped with a proper fill cap?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. If required, is the tank protected from vehicle impact?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
6. Is the tank equipped with a proper gauge and overfill protection device (whistle)?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
7. Is the tank properly supported on a firm base?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
8. If two tanks are joined, are they installed on a common slab?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
9. If two tanks are bottom connected, are they connected with a 2 in. pipe?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
10. Is the system free of leaks or any signs of weepage?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
11. Is the tank and piping painted or coated to prevent external corrosion?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
12. Are burner supply/return lines free of compression fittings?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
13. Are burner supply/return lines installed above grade and protected of underground and chased?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
14. Are burner supply/return lines installed to code?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
15. Is the tank support system in good condition, non-combustible and stable?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
16. If required, is the tank (over 2500L) protected with appropriate secondary containment?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
17. Is an approved shut-off valve installed?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
18. Is the fill/vent pipe steel or galvanized construction?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
19. Is an approved filter installed with a temperature rating above 538°C (1000°F)?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

NOTES: (any "NO" answers must be explained in this section and the affected equipment repaired, replaced or tagged)

Comments	Technician's Signature
	Certificate No.
	Date



136 Cannon Street West
Hamilton, ON L8R 2B9
Tel.: 905-528-0241
Fax: 905-667-0210



FUEL OIL DISTRIBUTOR INSPECTIONS

Appliances - Comprehensive

OWNER/OPERATOR _____

LOCATION _____ TEL. NO. _____

OWNER'S ADDRESS (If different from above) _____

	1st Appliance	2nd Appliance
Type of Appliance		
Manufacturer		
Model		
Date of Manufacture or Age in Years		
Size (BTU/Hr)		
Serial No.		
1. Is the appliance approved?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
2. Is the appliance installed in accordance with the fuel oil code?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
3. Is the appliance being used in accordance with its approval?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Is the appliance venting installed in accordance with the fuel oil code?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. Is the venting system free of defects, debris or corrosion?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
6. Is the vent sized properly?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
7. Is the proper combustion and ventilation air openings installed?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
8. Is the installation free of indications of heat exchanger cracks, defects in the refractory, pot and/or heat shields?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
9. Are all limits and safety controls properly installed?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
10. Is the appliance installed with appropriate clearances from combustibles?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
11. Are the results of combustion analysis acceptable?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
12. If required, is there a proper chimney cleanout?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
13. Is the chimney properly lined?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
14. Is the vent liner fitted with proper flashing, cap and base T?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A
15. If there is a sidewall vent attached to the appliance is it installed according to code and the manufacturer's instructions?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A

NOTES: (any No answers must be explained in this section and the affected equipment repaired, replaced or tagged)

Comments:	Company:
	Technician's Signature:
	Print Name:
	Certificate No.:
	Date: